



SOUND RATINGS

| S/M | Type | Test Date | Test No. | Overall IG | Ext Glazing | Airspace | mid | Air Space | Interior Glazing | Results | |
|-------------|-------------------|-----------|------------|------------|-------------|----------|-----------|-----------|------------------|---------|------|
| | | | | | | | | | | STC | OITC |
| 6000 series | Fixed | 12/4/2023 | Q2019.01 | 1-3/16" | 1/4" lami | 1/2" | 3/16"ann | 5/16" | 5/32" ann | 35 | 29 |
| | | 12/4/2023 | Q2019.01 A | 1-1/8" | 1/8" lami | 3/8" | 5/32" ann | 3/8" | 1/8" ann | 28 | 23 |
| | | 12/4/2023 | Q2019.01 B | 1-3/32" | 3/32" lami | 3/8" | 3/32" ann | 7/16" | 3/32" ann | 26 | 21 |
| | | 12/4/2023 | Q2019.01 C | 3/4" | 3/4" ann | 1/2" | N/A | N/A | 1/8" ann | 30 | 25 |
| 6000 series | Horizontal slider | 12/5/2023 | Q2021.01 A | 1-1/4" | 1/4" lami | 3/8" | 5/32" ann | 5/16" | 3/16" ann | 37 | 29 |
| | | 12/5/2023 | Q2021.01 B | 1-1/8" | 3/32" lami | 7/16" | 3/32" ann | 7/16" | 3/32" ann | 26 | 20 |
| | | 12/5/2023 | Q2021.01 C | 1-1/16" | 1/8" lami | 3/8" | 5/32" ann | 3/8" | 1/8" ann | 27 | 22 |
| | | 12/5/2023 | Q2021.01 D | 3/4" | 1/8" ann | 1/2" | N/A | N/A | 1/8" ann | 27 | 23 |
| 6000 series | Single Hung | 12/6/2023 | Q2022.01 A | 1-1/4" | 1/4" lami | 3/8" | 5/32" ann | 5/16" | 3/16" ann | 35 | 29 |
| | | 12/6/2023 | Q2022.01 B | 1-1/8" | 1/8" lami | 3/8" | 5/32" ann | 3/8" | 1/8" ann | 28 | 23 |
| | | 12/6/2023 | Q2022.01 C | 1-3/32" | 3/32" lami | 3/8" | 3/32" ann | 7/16" | 3/32" ann | 26 | 20 |
| | | 12/6/2023 | Q2022.01 D | 3/4" | 1/8" ann | 1/2" | N/A | N/A | 1/8" ann | 27 | 23 |